



4-7.2KW @ 120VAC
(PARALLEL) 50A BYPASS

4-5KW @ 120VAC
(PARALLEL)

7-7.2KW @ 120VAC
(PARALLEL)

24V: TWO 175A BRKRS
TWO PAIR 2/0 CABLES
48V: TWO 100A BRKRS
TWO PAIR 2/0 CABLES

24V: TWO 250A BRKRS
TWO PAIR 4/0 CABLES
48V: TWO 175A BRKRS
TWO PAIR 2/0 CABLES

BATTERY

4KW = 2 FX2024
5KW = 2 FX2548
14KW = 4 VFX3524
14.4KW = 4 VFX3648

Quanspeed
Power Systems

ALL BREAKERS SHOWN,
BYPASS MECHANISM,
AND TERMINAL BLOCKS
ARE STANDARD IN THE
OUTBACK PS2AC50D

19009 62nd AVE NE
ARLINGTON, WA, 98223
360-435-6030
4-7.2KW-50A-BYPASS-PAR