



X-240
#1 #283 #4
L2 N L1

8-14.4kW @ 120/240VAC
(SERIES) 100A BYPASS

8-10kW @ 120/240VAC
(SERIES)

14-14.4kW @ 120/240VAC
(SERIES)

24V: FOUR 175A BRKRS
FOUR PAIR 2/0 CABLES
48V: FOUR 100A BRKRS
FOUR PAIR 2/0 CABLES

24V: FOUR 250A BRKRS
FOUR PAIR 4/0 CABLES
48V: FOUR 175A BRKRS
FOUR PAIR 2/0 CABLES

BATTERY

8kW = 4 FX2024
10kW = 4 FX2548
14kW = 4 VFX3524
14.4kW = 4 VFX3648

**ALL BREAKERS SHOWN,
BYPASS MECHANISM,
X-240 AND TERMINAL
BLOCKS ARE HOUSED
IN THE OUTBACK PSAC**



19009 62nd AVE NE
ARLINGTON, WA. 98223
360-435-6030
8-14.4kW-100A-BYPASS-SER